## Installation Guide - GreaseShield®3000-F



- 1 GS3000-F Unit: Ensure that there is sufficient clearance above and to the right of the unit for servicing purposes (5.9"/150mm minimum).
- 2 Inlet Pipe 2"/54mm: To be piped with a sufficient fall of no less than 1 in 40. A flexible rubber pipe adaptor may be required if the incoming pipework is not 2"/54mm.
- 3 Outlet Pipe 3"/76mm: To be piped with a sufficient fall of no less than 1 in 40. A flexible rubber pipe adaptor may be required if the outgoing pipework is not 3"/76mm.
- 4 Decant Outlet Hose 3/4"/18mm: To be piped directly into the main drainage pipe via a vented drainage stack as shown. The Hose must be fixed in place using the the drainage hose support provided.
- 5 FS4000: Ensure sufficient height above the FS4000 Pre-Filter to allow for removal and daily maintenance of FS4000 Filter basket.
- FS4000 Filter Basket: A Filter basket must be installed into the pre-filter at all times.
- **7 FS4000 Manifold Lid:** The lid of the FS4000 Pre-Filter must be in place during normal operation and should only be removed for daily maintenance.
- 8 Running Trap: The outlet of unit must be fitted with a running trap to reduce foul smells. A 4"/110mm low-back running trap can be used to align with the outlet of the GS3000 unit. A flexible rubber pipe adaptor should be used.
- FOG Container: Ensure that the container are not restricted or blocked for daily maintenance.
- 10 Hot Water Solenoid Valve: Hot water must be connected to the unit using the ¾" BSP (F/F) Red PVC Hose provided, water supply must not exceed 3 bar pressure and 60°C/140°F. In the case of high pressure a pressure reducing valve must be used. Mains water connections must be made via a WRAS approved isolation valve which follows a WRAS approved double check valve.
- 1 Power Lead: The unit must be plugged into a 13 amp rated IP56 socket located below counter level.
- Interconnecting Pipework: All pipework must be clipped and properly supported.

V3 07/02/2020

## Installation Guide - GreaseShield®3000-F





- Make sure the unit is installed on level ground or adjust the stand feet to ensure the unit is level.
- Have a hot water connection available to connect to the unit, if one is not available the unit must be equipped with a Genie H2O to give hot water on demand. Water connection must be made via a WRAS approved isolation valve 🗛 and double check valve B



- Have an IP56 rated socket cbelow counter level available to the unit to plug into. If a genie H2O is required ensure an additional power supply (preferably a fuse spur) is available. Ensure all pipe work into and out of the unit has at least a 1 in 40 fall (downwards angle of 1.5°).
- Clean the FS4000 Pre-Filter basket and FOG container daily.
  If the main waste pipe is not vented then an Air Admittance Valve (not shown) must be installed after the running trap so a siphon doesn't occur.
- The Decant Outlet Hose Eneeds to be plumbed into a draingae stack, using the drain hose support provided.



- Place the unit in passageways where it can be a hazard or be damaged.
- Open the unit or insert hands into any part of the unit; moving parts can cause injury.
- Stand or place heavy objects on top of the unit.
- **DON'T** Dismantle the unit in any way, only qualified service staff are to access the inside of the unit.

V3 07/02/2020